

BUILDING SAFETY CERTIFICATE

No. 04/1Bhawam/AEI


Dated: 15-01-2024

Certified that the existing building M.J.R. Phule Public School (name of the building or premises) at Jagdishburam, Ghazipur (U.P.) (address) comprised of one Number basement(s) and (G+3) Floor (upper floors) owned/occupied by M. J. R. Phule Public School, Jagdishburam, Ghazipur (U.P.) (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of Provincial Div, P.W.D. GZP. (Name of Department/ Govt.) on 10.01.2024 (date of inspection) in the presence of Sri Rajesh Kushwaha, Manager, Shekhpura, GZP. (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes 1st upto XII (X/ XII) with effect from 15.01.2024 for a period of 5 years years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Essential Conditions required & complied by School Management
2. as per check list attached herewith.
- 3.
- 4.

Issued on 15.01.2024 at 03:00 PM by

* Strike out whichever is not applicable.

Signature with Seal : 
 Assistant Engineer
 P.D., P.W.D.
 Ghazipur
 Name : Khurshed Ahmad
 Designation : Assistant Engineer

Name & Address of Department/ Office: Provincial Div. P.W.D, GZP.


(Assistant Engineer & above officer of concerned Govt. Department only)

Note: This certificate should be signed / issued by Assistant Engineer & above officer of concerned Govt. Department only

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Checklist for school safety, especially earthquake(N.B.C.)/fire safety Checklist for CBSE/ICSE School (Class-1 to 12)

SNO.	Security related technical points	Investigation report
1.	Has the building plan been prepared by a registered engineer?	Yes
2.	Is the building map approved by the local body/authority/competent officer?	Yes
3.	Is the building more than three stories high?	No
4.	Is the minimum area of land for a building 0.180 hectares?	Yes
5.	Is there 6.0 meters of open space around the building?	Yes
6.	Is there proper parking arrangement in the building? Is there parking in the set bank of the building?	Yes
7.	Is the orientation of the building such that there is adequate air circulation?	Yes
8.	Is the width of the main access road a minimum of 12 metres?	Yes
9.	Is the building made of R.C.C.? If not, then was inflammable material not used in the construction of the roof?	Total R.C.C.
10.	Are the walls of the building made of brick or stone cement mortar?	Brick Masonry
11.	Are there cracks in the walls/roofs of the building?	No
12.	Is the height of the ceilings of the rooms a minimum of 3.6 meter (3.0 meter in cold region) from the floor meter?	3.60 Meter
13.	Is the width of the main entrance(Boundary wall) of the school 6.0 meters and height 4.0 meters?	Yes
14.	Is the area of windows a minimum of 10% of the floor area of the room? Is wood used in the windows?	Yes
15.	Does the room have a minimum of two doors?	Yes
16.	What is the minimum size of room doors (width 1.m, height 2.0 m)?	Yes
17.	Is there a provision for minimum two stairs if the school building has two stories or more?	Yes
18.	Is the width of the staircase in a building more than one floor high, minimum 1500 mm, tread 300 mm and riser 150 mm?	Yes
19.	Are fire extinguishers and automatic sprinkler systems installed at proper places in the building?	Yes
20.	Is there provision for first aid fire-fighting equipment in the building?	Yes
21.	Are school students/teachers given fire safety training from time to time?	Yes
22.	Is First Aid Box available at appropriate places in the school?	Yes


 Assistant Engineer
 Provincial Section P.W.D.
 Ghazipur